

Tabulka místností													
číslo místn.	Název místnosti	Plocha místn. m <sup>2</sup>	Výška místn. m	Objem místn. m <sup>3</sup>	Výměna xh <sup>-1</sup>	Přívod m <sup>3</sup> h <sup>-1</sup>	Odvod m <sup>3</sup> h <sup>-1</sup>	Podtl. %	Přetl. %	č.zař. přívod	č.zař. odvod	Tepelné zisky	Poznámka
	objekt A												
	1.NP												
1.27	schodiště	33,70	3,00	101	0,0	0	0	0	0			3,6	
1.29	kontaktní pracoviště	171,00	3,50	599	3,0	1 800	1 800	0	0			21	
2.12	schodiště	33,70	3,00	101	0,0	0	0	0	0			3,6	
2.14	kanceláře	171,00	3,50	599	3,0	1 800	1 800	0	0			21	
3.12	schodiště	33,70	3,00	101	0,0	0	0	0	0			3,6	
3.14	kanceláře	171,00	3,50	599	3,0	1 800	1 800	0	0			21	
				Součet		5 400	5 400					73,8	
	větrání garáží												
S2.03	garáž	643,10	2,50	1608	2,5	4 020	4 020	0	0				
S1.03	garáž	1040,10	2,50	2600	2,5	6 510	6 510	0	0				
S1.11	garáž	678,80	2,50	1697	2,5	4 250	4 250	0	0				
1.03	garáž	1045,20	2,50	2613	2,5	6 540	6 540	0	0				
1.11	garáž	587,90	2,50	1470	2,5	3 680	3 680	0	0				
2.03	garáž	1045,20	2,50	2613	2,5	6 540	6 540	0	0				
2.11	garáž	1097,90	2,50	2745	2,5	6 870	6 870	0	0				
3.03	garáž	1045,20	2,50	2613	2,5	6 540	6 540	0	0				
3.11	garáž	1097,90	2,50	2745	2,5	6 870	6 870	0	0				
4.03	garáž	1045,20	2,50	2613	2,5	6 540	6 540	0	0				
4.11	garáž	1097,90	2,50	2745	0,0	0	0	0	0				venkovní stání
				Součet		58 360	58 360						
	Větrání CHUC I												
S2.01	schodiště	25,50	2,80	71	10,0	720	0	0	100				
	chodba	0,00	0,00	0	0,0	0	0	0	100				
S1.01	schodiště	25,50	2,80	71	10,0	720	0	0	100				
	chodba	0,00	0,00	0	0,0	0	0	0	100				
1.01	schodiště	25,50	2,80	71	10,0	720	0	0	100				
1.13	chodba	73,40	2,80	206	10,0	2 060	0	0	100				
1.35	chodba	4,85	2,80	14	10,0	140	0	0	100				
2.01	schodiště	25,50	2,80	71	10,0	720	0	0	100				
	chodba	0,00	0,00	0	0,0	0	0	0	100				
3.01	schodiště	25,50	2,80	71	10,0	720	0	0	100				
	chodba	0,00	0,00	0	0,0	0	0	0	100				
4.01	schodiště	25,50	2,50	64	10,0	640	0	0	100				
	chodba	0,00	0,00	0	0,0	0	0	0	100				
				Součet		6 440	0					0	
	Větrání CHUC II												
S2.06	schodiště	31,00	2,80	87	10,0	870	0	0	100				
	chodba	0,00	0,00	0	0,0	0	0	0	100				
S1.06	schodiště	31,00	2,80	87	10,0	870	0	0	100				
	chodba	0,00	0,00	0	0,0	0	0	0	100				
1.06	schodiště	31,00	2,80	87	10,0	870	0	0	100				
1.12	chodba	26,87	2,80	75	10,0	760	0	0	100				
1.36	chodba	5,13	2,80	14	10,0	150	0	0	100				
2.06	schodiště	31,00	2,80	87	10,0	870	0	0	100				
	chodba	0,00	0,00	0	0,0	0	0	0	100				
3.06	schodiště	31,00	2,80	87	10,0	870	0	0	100				
	chodba	0,00	0,00	0	0,0	0	0	0	100				
4.06	schodiště	31,00	2,50	78	10,0	780	0	0	100				
	chodba	0,00	0,00	0	0,0	0	0	0	100				
				Součet		6 040	0					0	
	Větrání CHUC III												
S2.11	schodiště	35,80	4,85	174	10,0	1 740	0	0	100				
	chodba	0,00	0,00	0	0,0	0	0	0	100				
	schodiště	35,80	0,00	0	10,0	0	0	0	100				
	chodba	0,00	0,00	0	0,0	0	0	0	100				
1.27	schodiště	33,70	4,00	135	10,0	1 350	0	0	100				
	chodba	0,00	0,00	0	10,0	0	0	0	100				
2.12	schodiště	33,70	3,42	115	10,0	1 160	0	0	100				
	chodba	0,00	0,00	0	0,0	0	0	0	100				
3.12	schodiště	33,70	3,52	119	10,0	1 190	0	0	100				
	chodba	0,00	0,00	0	0,0	0	0	0	100				
				Součet		5 440	0					0	